

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XS793		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SCHOPEN, ROBBY						Phone # (757)705-1771		1. Well Location				Fire # (if avail.)					
Mailing Address 9120 ANGELICA DR						Town of DUNBAR						N1812					
City STURTEVANT						State WI		Zip Code 53177				Street Address or Road Name and Number					
N18126 LILY LAKE LN						Subdivision Name				Lot #		Block #					
County Marinette		Co. Permit #		Notification # 6862746601		Completed 06-28-2017		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Well Constructor (Business Name) JEREME ROMITTI				Lic. # 6067		Facility ID # (Public Wells)				45.6129 °N -88.1064 °W		GCD013					
Address W8859 COUNTY N NIAGARA WI 54151-0153				Well Plan Approval #		NW NE		Section 10		Township 36 N		Range 19 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		10		36 N		19 E					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.9		2. Well Type New Well				of previous unique well # constructed in							
3. Well serves 1 # of CAMPER Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ?									
						Hicap Property ? No											
						Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) 6		From (ft.) Surface		To (ft.) 43		Upper Enlarged Drillhole				Lower Open Bedrock		8. Geology					
						Rotary - Mud Circulation				Geology Codes - - S -		Type, Caving/Noncaving, Color, Hardness, etc... SAND		From (ft.) Surface		To (ft.) 15	
						Rotary - Air				- - X G		CLAY, SAND & GRAVEL		15		25	
						Rotary - Air & Foam				- - Y G		SAND, GRAVEL & BOULDERS		25		35	
						Drill-Through Casing Hammer				- - Y -		SAND & GRAVEL		35		43	
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen																	
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 40		9. Static Water Level				11. Well Is			
		WHEATLAND USA PE. 18.97 LB/FT								15 ft. below ground surface				14 in. above grade			
Dia. (in.) 6		Screen type, material & slot size				From (ft.) 39		To (ft.) 43		10. Pump Test				Developed ? Yes			
		S.S. CONT SLOT #15								Pumping level 35 ft. below surface				Disinfected ? Yes			
										Pumping at 18 GP M for 0.5 Hrs.				Capped ? Yes			
										Pumping Method ?							
7. Grout or Other Sealing Material																	
Method POURED/MOUNDED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?									
#8 GRANITE BENTONITE		Surface		40		3 S											
Filled & Sealed Well(s) as needed? NONE																	
13. Constructor / Supervisory Driller																	
Lic #		Date Signed															
JR		06-30-2017															
Drill Rig Operator		Lic or Reg #		Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Shoreline/Pool	>	300

Comment:

Created On: 07-25-2017

Updated On: 10-22-2019

Review Status: