

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XS796		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HENDRICKSON, CLARENCE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address N18343 BIG BEAR RD						Town of PEMBINE						N1834							
City PEMBINE						State WI		Zip Code 54156				Street Address or Road Name and Number BIG BEAR RD							
County Marinette		Co. Permit #		Notification # 6914780801		Completed 08-24-2017		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) JEREME ROMITTI				Lic. # 6067		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.6187 °N -87.8641 °W				Method Code GCD013					
Address W8859 COUNTY N NIAGARA WI 54151-0153				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 4 3 36 N 21 E				2. Well Type New Well									
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		Reason for replaced or reconstructed well ?				Construction Type Drilled									
3. Well serves 1 # of				Hicap Well ? No															
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		10		Rotary - Mud Circulation <u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - S -		SAND		Surface		5			
6		10		163						- - Z S		SANDY CLAY, COBBLES		5		85			
										- - Z S		SANDY CLAY, GRAVEL		85		121			
										- - G M		SILT, GRAVEL, STONE		121		122			
										R - H -		RED SHALE		122		163			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		54 ft. below ground surface				18 in. above grade					
6		WHEATLAND USA A53-B P.E. 18.97 LB/FT				Surface		122		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 150 ft. below surface				Disinfected ? Yes					
										Pumping at 8 GP M for 4 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method POURED/MOUNDED												Filled & Sealed Well(s) as needed? No NONE							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
#8 GRANULAR BENTONITE		Surface		123		8 S													
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												JR						08-29-2017	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		45	Privy		62
			Animal Yard - Include Hutches		59

Comment:

Created On: 10-09-2017

Updated On: 10-22-2019

Review Status: