

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XT243		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WALDVOGEL, TERRY						Phone # (715)506-0777		1. Well Location				Fire # (if avail.)					
Mailing Address N10884 CRESENT DR						Town of NORWOOD						Street Address or Road Name and Number W8046 MOOSE LK RD					
City BIRNAMWOOD				State WI		Zip Code 54414											
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #			
Langlade		6717588201		03-29-2016		Latitude / Longitude in Decimal Degree (DD) 45.07292 °N -89.0497 °W				Method Code GPS006							
Well Constructor (Business Name) KOEPPPEL PHIL WELL DRLG LLC				Lic. # 6626		Facility ID # (Public Wells)				NW NE Section Township Range or Govt Lot # 21 30 N 12 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME ON VACANT LOT FORMER COTTAGE					
Address W8060 PARK RD ANTIGO WI 54409				Well Plan Approval #		Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 18				Construction Type Drilled							
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method						8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
5		Surface		31		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		- V S M - Q Y -		NONCAVING SILTY SAND CAVING SAND & GRAVEL		Surface		4 31			
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		2 ft. below ground surface				24 in. above grade			
5		BLACK STEEL A53B 14.62 #/FT. .280IN WELDED IPSCO				Surface		28		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 3 ft. below surface Pumping at 18 GP M for 1 Hrs. Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes			
5		SS ALLOY TELESCOPE .018				28		31									
7. Grout or Other Sealing Material						13. Constructor / Supervisory Driller						Lic #		Date Signed			
Method MOUNDED						MPK						04-10-2016					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Drill Rig Operator				Lic or Reg #		Date Signed	
#8 WYO BEN				Surface		0.5 S		Yes				Yes					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Shoreline/Pool		96	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 05-12-2016

Updated On: 06-12-2020

Review Status: