Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XT244

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STEGER, ED	Phone #: (715)627-0594
Mailing Address: W8046 MCINTOSH DR	
City: ANTIGO	State: WI — Zip Code: 54409
County: Langlade	Co. Permit #:
Notification #: 6392894501	Completed: 04-26-2016
Well Constructor (Business Name): KOEPPEL PHIL WELL DRLG LLC	Lic. #: 6626
Facility ID # (Public Wells):	
Address: W8060 PARK RD ANTIGO WI 54409	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3.6	

1. Well Location

Town of ELCHO

Fire # (if avail.):

Street Address or Road Name and Number: N10678 SUNSET LN

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.416 °N -89.0847 °W	GCD013

SE NW or Govt Lot #	Section	Township	Range
	23	34 N	11 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of COTTAGE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	37

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- Q Y -	CAVING SAND & GRAVEL	Surface	37

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	BLACK STEEL A53B 14.62 #/FT .258IN WELDED IPSCO	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS ALLOY TELESCOPE .012IN	34	37

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 19 ft. below surface

Pumping at 18 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE FOUND

13. Constructor / Supervisory Driller	Lic #	Date Signed
MPK		05-07-2016
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Shoreline/Pool		60	Septic or Holding, or POWTS Tank		30

Comment:

Created On: 06-15-2016 Updated On: 06-12-2020 Review Status: