Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XT245

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JUNTUNEN, PETE	Phone #: (720)532-0925
Mailing Address: 3026 GOLDEN BEAR CT	
City: DE PERE	State: WI — Zip Code: 54115
County: Langlade	Co. Permit #:
Notification #: 6395332201	Completed: 04-27-2016
Well Constructor (Business Name): KOEPPEL PHIL WELL DRLG LLC	Lic. #: 6626
Facility ID # (Public Wells):	
Address: W8060 PARK RD ANTIGO WI 54409	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 4.5	

1. Well Location

Town of ELCHO	Fire # (if avail.): N10956
Street Address or Road Name and Number: CIRCLE DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.4255 °N -89.0954 °W	Method Code: GCD013
SE SE or Govt Lot #:	Section: 15 — Township: 34 N — Range: 11 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: FAILING POINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
5	Surface	45.5

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	V	S	M	NONCAVING SILTY SAND	Surface	4
-	Q	Y	-	CAVING SAND & GRAVEL	4	45.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	BLACK STEEL A53B 14.62 #/FT. .258IN WELDED IPSCO	Surface	42.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS. ALLOY TELESCOPE .018	42.5	45.5

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 WYOBEN	Surface		0.5 S

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 18 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

BY PUMP INSTALLER

13. Constructor / Supervisory Driller	Lic #	Date Signed
MPK		05-07-2016
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		51	Shoreline/Pool		99
Building Overhang		2	Septic or Holding, or POWTS Tank		33

Comment:

Created On: 06-15-2016 Updated On: 06-12-2020 Review Status: