Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XT331

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BENSON, MIKE			Phone #
Mailing Address: 7410 GLEASON RD			
City: EDINA	State: MN	Zip Code: 55439	
County: Polk	Co. Permit #:	Notification #: 55817064	Completed: 09-01-2015

Well Constructor (Business Name): LARRY C COX	Lic. #: 5324	Facility ID # (Public Wells):	
Address: MILLTOWN PUMP SERVICE MILLTOWN WI 54858		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of MILLTOWN					Fire # (if avail.): 1837
Street Address or Road Name and Number: 1837 PINE ISLAND PARK CT					
Subdivision Name: PINE ISLAND PARK			Lot #: 14		Block #: NA
Latitude / Longitude in Decimal Degree (DD): 45.4745 °N -92.4357 °W					Method Code: GCD013
NW	SE	Section: 35	Township: 35 N		Range: 17 W
or Govt Lot #					

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: PLUGGED SCREEN

Construction Type: Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

6. Casing, Liner, Screen Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	CODE PIPE	Surface	29
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	CAMPBELL SS X 60 GA	29	32

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE CHIPS	Surface	28	1 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	-	X	-	BROWN SD-CLAY	Surface	20
-	-	C	-	CLAY	20	28
-	-	S	-	SAND	28	32

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 10 ft. below surface

Pumping at 7 GP for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
LCC		09-23-2015
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50
Building Drain - Sanitary		25
Building Overhang		2
Downspout/Yard Hydrant		8
Foundation Drain to Clearwater		25

Type	Qualifier	Distance
Foundation Drain to Sewer		25
Shoreline/Pool		25
Landfill		1500
Sewer - Building Sanitary		25
Septic or Holding, or POWTS Tank		25

Comment: WELL SAMPLE STATES WELL COMPLETION DATE IS 9/1/15, SO I CORRECTED THE WCR FROM 2003. DLR

Created On: 11-11-2015 Updated On: 10-15-2026 Review Status: