Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XU098

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MACHKOVICH, JOE			Phone #: (920)437-3001
Mailing Address: 808 ASH ST			
City: GREEN BAY	State: WI	Zip Code: 54313	
County: Marinette	Co. Permit #:	Notification #: 6888337101	Completed: 07-27-2017

Well Constructor (Business Name): GERALD L COOPER	Lic. #: 6211	Facility ID # (Public Wells):	
Address: 5050 BROWN RD LITTLE SUAMICO WI 54141		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of STEPHENSON

Fire # (if avail.): W1123

Street Address or Road Name and Number: PALLOCK RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.32348 °N	-88.1599 °W			GPS006
SE NW or Govt Lot #	Section: 20	Township: 33 N	Range: 19 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.5	Surface	4
6	4	42

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 8in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T S S -	SAND, CAVING, TAN, SOFT	Surface	42

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LB PER FT ASTM A53 EXL TUBE WELDED	Surface	39
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SLOTTED STAINLESS 8 SLOT	39	42

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 31 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CRUMBLES & DRILLING MUD	Surface	39	1 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
GLC		08-28-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		52	Building Overhang		30
Building Drain - Sanitary		54	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 09-12-2017 Updated On: 09-12-2017 Review Status: