

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XU346		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BECKMAN, SHAWN						Phone # (715)218-7424		1. Well Location				Fire # (if avail.)	
Mailing Address 611 POPLAR ST						Town of MERRILL						Street Address or Road Name and Number N2342 VISTA DR	
City MERRILL			State WI		Zip Code 54452		Subdivision Name				Lot # Block #		
County Lincoln		Co. Permit #		Notification # 57356558		Completed 12-09-2015		Latitude / Longitude in Decimal Degree (DD) 45.20122 °N -89.73265 °W				Method Code GPS006	
Well Constructor (Business Name) JESSE W BRUNNER				Lic. # 4379		Facility ID # (Public Wells)		SW NW Section Township Range or Govt Lot # 3 31 N 6 E		2. Well Type New Well			
Address N3410 CASTLE RD MEDFORD WI 54451				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in					
Hicap Permanent Well #			Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?						
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
10		Surface		10		Rotary - Mud Circulation							
6		10		140		<u>Yes</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T	-	Y	U	DIRTY BROWN SAND & GRAVEL				Surface		19			
T	E	Y	-	CLEAN BROWN SAND & GRAVEL				19		30			
T	-	C	G	BROWN CLAY & STONES				30		36			
G	-	Y	U	DIRTY GRAY SAND & GRAVEL				36		42			
T	-	C	G	DK. BROWN/GRAY CLAY W/STREAKS OF MUDDY GRAVEL				42		50			
T	D	Q	-	DECOMPOSED BROWN GRANITE W/FIRM LAYERS				50		70			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW BLACK STEEL T&C A53B 19.45#/FT. .280 WALL WHEATLAND				Surface		71					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement DRILL CUTTINGS Surface 10 S													
9. Static Water Level 22 ft. below ground surface													
10. Pump Test Pumping level 130 ft. below surface Pumping at 4 GP M for 1 Hrs. Pumping Method ?													
11. Well Is 30 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller Lic # Date Signed JWB 01-20-2016 Drill Rig Operator Lic or Reg # Date Signed													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54	Sewer - Building Sanitary		24
Building Overhang		24	Septic or Holding, or POWTS Tank		90

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	12/09/2015	WE ARE THE PUMP INSTALLER & SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED.

Created On: 02-08-2016

Updated On: 06-15-2020

Review Status: