

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XU352		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DUNN, ZACH						Phone # (715)314-2088		1. Well Location				Fire # (if avail.)							
Mailing Address N3405 DIVISION DR						Town of HAMMEL						Street Address or Road Name and Number N3405 DIVISION DR							
City MEDFORD			State WI		Zip Code 54451			Subdivision Name				Lot #		Block #					
County Taylor		Co. Permit #		Notification # 57349922		Completed 12-08-2015		Latitude / Longitude in Decimal Degree (DD) 45.15452 °N -90.49493 °W				Method Code GPS006							
Well Constructor (Business Name) JESSE W BRUNNER				Lic. # 4379		Facility ID # (Public Wells)		SW NE Section Township Range or Govt Lot # 21 31 N 1 W		2. Well Type New Well			of previous unique well # constructed in						
Address N3410 CASTLE RD MEDFORD WI 54451				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ?											
Hicap Permanent Well #			Common Well #		Specific Capacity 2.5		Construction Type Drilled												
3. Well serves 1 # of MOBILE HOME						Hicap Well ? No		Private, potable											
Heat Exchange ___ # of drillholes						Hicap Property ? No		Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		10		Rotary - Mud Circulation				- - I -		TOPSOIL		Surface		1			
6		10		27		<u>Yes</u> Rotary - Air <u>No</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				T - C -		BROWN CLAY		1		4			
										T - G G		DIRTY DK BROWN GRAVEL & STONES		4		15			
										G E Y -		CLEAN GRAY SAND & GRAVEL		15		26			
										T E S -		CLEAN FINE DK BROWN SAND		26		27			
6. Casing, Liner, Screen												8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 4 ft. below ground surface				11. Well Is 24 in. above grade					
6		NEW BLACK STEEL T & C A53B 19.45 #/FT .280 WALL WHEATLAND				Surface		25.5		10. Pump Test Pumping level 8 ft. below surface Pumping at 10 GP M for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
5.5		SS #12				25.5		27											
7. Grout or Other Sealing Material Method												13. Constructor / Supervisory Driller				Lic #		Date Signed	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		JWB						12-09-2015			
DRILL CUTTINGS				Surface		10				Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		4	Sewer - Building Sanitary		32
			Septic or Holding, or POWTS Tank		30

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	12/08/2015	WE ARE THE PUMP INSTALLER & SAMPLE WILL BE TAKEN AFTER PUMP IS INSTALLED

Created On: 12-22-2015

Updated On: 06-10-2020

Review Status: