

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XU536		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner TEEZLAFL, STEVE						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 364 LAKE SHR RD						Town of GRAFTON													
City GRAFTON						State WI		Zip Code 53024											
County Ozaukee		Co. Permit #		Notification # 7049540701		Completed 12-15-2017		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) ARTHUR JAMES LIEBAU				Lic. # 23		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.29022 °N -87.90435 °W				Method Code GPS008					
Address 1200 W LIEBAU RD MEQUON WI 53092				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 33 10 N 22 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD 5 INCH WELL NO WATER											
Hicap Permanent Well #				Common Well #		Specific Capacity 1.5													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		245		Rotary - Mud Circulation <u>No</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - C -		CLAY		Surface		145			
										- - P -		HARDPAN		145		151			
										- - L -		LIMESTONE		151		245			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		135 ft. below ground surface				18 in. above grade					
6		ASTM A53 GR. B .280 WALL, EXL TUBE P.E. WELDED				Surface		151		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 145 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE				Surface				3 S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												AL						12-18-2017	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Clearwater Sump		25
Building Overhang		20	Wastewater Sump		40

Comment:

Created On: 01-09-2018

Updated On: 07-15-2019

Review Status: