Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XV774

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: NEIDERMIRE, DOUG	Phone #: (612)718-8894
Mailing Address: 947 190TH ST	
City: DRESSER	State: WI — Zip Code: 54009
County: Polk	Co. Permit #:
Notification #: 6406055401	Completed: 05-13-2016
Well Constructor (Business Name): BRUCE SAMPSON	Lic. #: 3819
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: SAMPSON WELL CO FOREST LAKE MN 55025	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity:	

1. Well Location

Town of OSCEOLA

Fire # (if avail.):

Street Address or Road Name and Number: 947 190TH ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.3444 °N -92.5527 °W

Method Code: GCD013

SE	NE	Section	Township	Range
or Govt Lot #		14	33 N	18 W

2. Well Type Replacement

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: OLD & UNSAFE IN A PIT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	100

Upper Enlarged Drillhole: Yes

Lower Open Bedrock: No

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	S	Y	-	SAND/GRAVEL SOFT	Surface	51
-	M	C	-	CLAY MED	51	98
-	S	G	-	GRAVEL SOFT	98	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	PVC SDR 21 CRESLINE GLUED	Surface	100
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
Q GROUT	Surface	100	7 S

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 25 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BS		05-27-2016
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Septic or Holding, or POWTS Tank		110

Comment:

Created On: 08-18-2016 Updated On: 06-30-2020 Review Status: