Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XW861

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ARNESON, EVELYN	Phone #: (715)703-0504
Mailing Address: 9801 CO HWY D	
City: BOYD	State: WI — Zip Code: 54726
County: Burnett	Co. Permit #:
Notification #: 6819683301	Completed: 05-25-2017
Well Constructor (Business Name): WILLIAM ARNOLD JR	Lic. #: 4514
Facility ID # (Public Wells):	
Address: BILL ARNOLD PUMP & WELL, DANBURY WI 54830	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.5	

1. Well Location

Town of WEBB LAKE	Fire # (if avail.): 3073
Street Address or Road Name and Number: 3073 HOLIDAY ACS DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.03063 °N -92.1382 °W	Method Code: GPS008
NW SE or Govt Lot #:	Section: 17 — Township: 41 N — Range: 14 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of SHOWERHOUSE
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	92.5

Upper Enlarged Drillhole / Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	Y	M	SILT, SAND, GRAVEL, COBBLES, CAVING	Surface	25
R	Q	X	M	FINE SAND, RED CLAY SILT, CAVING	25	40
R	H	C	-	RED CLAY HARD, NON CAVING	40	50
R	Q	C	S	SANDY RED CLAY, SOFT CAVING	50	70
T	Q	S	-	FINE SAND, BRN, CAVING	70	92.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	EXEL TUBE USA ASTM A53 SCH40 4.5 X .237 10.79 #/FT	Surface	88.5
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	T JOHNSON CONTINUOUS SLOT SS 7 SLOT	88.5	92.5

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		40 S

9. Static Water Level
53 ft. below ground surface

10. Pump Test
Pumping level 64 ft. below surface
Pumping at 16 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
WSA		06-17-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		135
Building Overhang		79
Shoreline/Pool		200
Privy		110
Sewer - Building Sanitary		88
Septic or Holding, or POWTS Tank		125

Comment:

Created On: 07-13-2017 Updated On: 01-08-2018 Review Status: