# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* XW864

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | | | |
|---|---|---|---|
| Property Owner: FRAZEE, ROBERT | | | Phone # |
| Mailing Address: 8848 N RIVER RD | | | |
| City: DANBURY | State: WI | Zip Code: 54830 | |
| County: Burnett | Co. Permit #: | Notification #: 6983719701 | Completed: 10-25-2017 |

| | | | |
|---|---|---|---|
| Well Constructor (Business Name): WILLIAM ARNOLD JR | Lic. #: 4514 | Facility ID # (Public Wells): | |
| Address: BILL ARNOLD PUMP & WELL<br>DANBURY WI 54830 | | Well Plan Approval #: | |
| | | Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: | Specific Capacity: | |

**3. Well serves** 1 # of BUNKHOUSE
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

**1. Well Location**

| | | | | |
|---|---|---|---|---|
| Town of SWISS | | | | Fire # (if avail.): 8848 |
| Street Address or Road Name and Number: 8848 N RIVER RD | | | | |
| Subdivision Name: | | | Lot #: | Block #: |
| Latitude / Longitude in Decimal Degree (DD): 45.98375 °N -92.43985 °W | | | | Method Code: GPS008 |
| SE SW or Govt Lot #: | Section: 36 | Township: 41 N | Range: 17 W | |

**2. Well Type** New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

Upper Enlarged Drillhole / Lower Open Bedrock
- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 2 | SCH. 40 GALV. ASTM A53 .154 WALL 3.75 #/FT. THREADED AND COUPLED | Surface | 36 |
| **Dia. (in.)** | **Screen type, material & slot size** | **From (ft.)** | **To (ft.)** |
| 2 | SIMMONS #1753-1 STAINLESS 60 GA | 36 | 40 |

**7. Grout or Other Sealing Material**

Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | | 15 S |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| - | - | S | - | SAND | Surface | 40 |

**9. Static Water Level**
26 ft. below ground surface

**10. Pump Test**
Pumping level 26 ft. below surface
Pumping at 8 GP M for 0.5 Hrs.
Pumping Method ?

**11. Well Is**
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**12.** Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| WSA | | 10-27-2017 |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| | | |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| Building Overhang | | 2 | Privy | | 75 |

Comment:

Created On: 11-14-2017 Updated On: 11-14-2017 Review Status: