

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XW879		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner WERY, DALE						Phone # (715)850-2071		1. Well Location				Fire # (if avail.)					
Mailing Address 16454 S BASS LK						Town of DOTY						16454					
City TOWNSEND						State WI		Zip Code 54175				Street Address or Road Name and Number 16454 S BASS LK LN					
County Oconto		Co. Permit #		Notification # 6948782201		Completed 09-14-2017		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) LLOYD J LEFEBER				Lic. # 6406		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.2743 °N -88.6181 °W				Method Code GCD013			
Address LLOYD'S MOUNTAIN PUMP SERVICE MOUNTAIN WI 54149				Well Plan Approval #		NE NE		Section 9		Township 32 N		Range 15 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? PULLED SAND IN											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Driven Point											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) 2		From (ft.) Surface		To (ft.) 46		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - Y - - - S -		SAND, GRAVEL SAND		Surface 43		43 46	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.) 2		Material, Weight, Specification T&C DRIVE PIPE (WHEATLAND)				From (ft.) Surface		To (ft.) 43		12 ft. below ground surface				16 in. above grade			
Dia. (in.) 2		Screen type, material & slot size S.S. #60 (MIDWEST 325)				From (ft.) 43		To (ft.) 46		10. Pump Test Pumping level 12 ft. below surface Pumping at 6 GP M for 2 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement Surface												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller LL												Lic #		Date Signed 09-17-2017			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Shoreline/Pool		150
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 01-09-2018

Updated On: 11-15-2019

Review Status: