

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XW962		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BASS, PAT						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address N3372 SAWYER CREEK RD								Town of BASHAW				N3372							
City SHELL LAKE						State WI		Zip Code 54871											
County Washburn		Co. Permit #		Notification # 6436515601		Completed 05-18-2016		Subdivision Name				Lot #							
												Block #							
Well Constructor (Business Name) BEECROFT JEREMY WELL DRLG & PUMP REP				Lic. # 6458		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.75606 °N -91.94798 °W									
Address W7414 MILLER RD SPOONER WI 54801				Well Plan Approval #		SW SW		Section 23		Township 38 N		Method Code GPS008							
				Approval Date (mm-dd-yyyy)		Range 13 W													
Hicap Permanent Well #				Common Well #		Specific Capacity 1.4				2. Well Type Replacement									
										of previous unique well #									
										Reason for replaced or reconstructed well ? SLOW WELL									
3. Well serves 1 # of				Hicap Well ? No						Construction Type Drilled									
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8.75		Surface		153		<u>Yes</u> Rotary - Mud Circulation				<u>No</u>		- - G G		GRAVEL, ROCK & BOULDERS		Surface		42	
						Rotary - Air						- - Y C		SAND, ROCKS & CLAY		42		145	
						Rotary - Air & Foam						- - Y -		SAND & GRAVEL		145		153	
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		85 ft. below ground surface				18 in. above grade					
5		SDR17 PVC CASING CEMENT SOLVENT WELD FORMATION STABILIZER				Surface		148		10. Pump Test				Developed ? Yes					
										Pumping level 120 ft. below surface				Disinfected ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 50 GP M for 1 Hrs.				Capped ? Yes					
5		10 SLOT S.S. SCREEN				148		153		Pumping Method ?									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?					
Method																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes					
EZ SEAL				Surface		140		13 S											
13. Constructor / Supervisory Driller								Lic #		Date Signed									
JB										05-24-2016									
Drill Rig Operator								Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		15
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 09-29-2016

Updated On: 10-05-2016

Review Status: