

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XX165		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner TLUSTY, JEROME Phone # (715)571-5432						1. Well Location				Fire # (if avail.)	
Mailing Address 405 COUNTRY CLUB RD						Town of WESTON					
City SCHOFIELD State WI Zip Code 54476						Street Address or Road Name and Number 405 COUNTRY CLUB RD					
County Marathon		Co. Permit #		Notification # 6592159201		Completed 10-06-2016		Subdivision Name		Lot #	Block #
Well Constructor (Business Name) EDWARD J DREWS				Lic. # 327	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.9091 °N -89.6284 °W			Method Code GCD013	
Address DREWS WELL DRLG RINGLE WI 54471				Well Plan Approval #		SW NW	Section 13	Township 28 N	Range 7 E		
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 4.5		2. Well Type Replacement of previous unique well # constructed in					
						Reason for replaced or reconstructed well ? LOW YIELD BASEMENT DRIVE POINT					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
6	Surface	31									
			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
-	V	S	-	NONCAVING SAND	Surface	4					
-	Q	Y	-	CAVING SAND & GRAVEL	4	31					
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)						
6	HYUNDAI A53B 18.97 WELDED			Surface	28						
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)						
5	STAINLESS 12 SLOT K-PAK			28	31						
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement							
CETCO #8		Surface		0.5 S							
9. Static Water Level											
11 ft. below ground surface											
10. Pump Test											
Pumping level 15 ft. below surface											
Pumping at 18 GP M for 1 Hrs.											
Pumping Method ?											
11. Well Is											
18 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
Lic #											
Date Signed											
MPK											
10-13-2016											
Drill Rig Operator											
Lic or Reg #											
Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		7	Sewer - Building Sanitary		28
Shoreline/Pool		27	Septic or Holding, or POWTS Tank		73

Comment:

Created On: 11-14-2016

Updated On: 05-11-2020

Review Status: