Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XX380

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TEMPLE, TAMMY			Phone #
Mailing Address: N987 ARBOR LAKE S			
City: LYNDON STATION	State: WI	Zip Code: 53944	
County: Juneau	Co. Permit #:	Notification #: 6980083001	Completed: 11-01-2017

Well Constructor (Business Name): DAVID WILLIAM SMITH	Lic. #: 38	Facility ID # (Public Wells):	
Address: D W SMITH WELL DRILLING, BARABOO WI 53913		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3	

1. Well Location

Town of LYNDON			Fire # (if avail.): N987
Street Address or Road Name and Number: N987 ARBOR LAKE S			
Subdivision Name: ARBOR LAKE	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 43.67328 °N -89.83557 °W			Method Code: GPS008

NE	SE	Section	Township	Range
or Govt Lot #		19	14 N	6 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	41
6	41	106

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 12in. dia
- Yes — Removed? 4depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	5
-	-	N	-	SANDSTONE	5	106

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM A53 18.97 GRADE B WELDED JOINT WHETLAND USA	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	41	12 S

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 42 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No
NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
DWS		12-10-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 02-19-2018 Updated On: 05-04-2020 Review Status: