

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XX503		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GILLETT, DAVID & LINDA						Phone # (952)896-1845		1. Well Location				Fire # (if avail.)	
Mailing Address 5622 HYLAND CTS DR						Town of BELL						21010	
City BLOOMINGTON						State MN		Zip Code 55437				Street Address or Road Name and Number	
County Bayfield						Co. Permit #		Notification # 6979270501				Completed 10-17-2017	
Well Constructor (Business Name) ROBERT T MELIN						Lic. # 111		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.8581 °N -91.1337 °W	
Address MELIN WELL DRILLING ASHLAND WI 54806-3825						Well Plan Approval #		NW NW		Section 33		Township 51 N	
								Range 6 W					
Hicap Permanent Well #						Common Well #		Specific Capacity				2. Well Type New Well	
Heat Exchange ___ # of drillholes						Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?	
3. Well serves 1 # of SUMMER CABIN						Hicap Potable ?		Construction Type Drilled				of previous unique well # constructed in	
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
10		Surface		128		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)			
- - I -		TOP SOIL						Surface		2			
- - S -		SAND						2		32			
- - C -		CLAY						32		105			
- N S -		SAND (FINE)						105		110			
- A S -		SAND (COURSE)						110		128			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level			
5		PVC-SDR-17-250PSI F450 EAGLE				Surface		108		___ ft. above ground surface			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is			
5		JOHNSON-15 SLOT-PVC				108		128		24 in. above grade			
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Developed ? Yes					
HEAVY BENTONITE SLURRY MIXED WITH DRILL CUTTINGS		Surface		108		S		Disinfected ? Yes					
Filled & Sealed Well(s) as needed?													
NONE ON PROPERTY													
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
RTM		10-21-2017											
Drill Rig Operator													
Lic or Reg #		Date Signed											
DR		10-21-2017											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary		60	Septic or Holding, or POWTS Tank		50

Comment: FLOWING STATIC WATER LEVEL & PUMP TEST

Created On: 11-14-2017

Updated On: 06-25-2020

Review Status: