Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XX503

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GILLETT, DAVID & LINDA			Phone #: (952)896-1845
Mailing Address: 5622 HYLAND CTS DR			
City: BLOOMINGTON	State: MN	Zip Code: 55437	
County: Bayfield	Co. Permit #:	Notification #: 6979270501	Completed: 10-17-2017

Well Constructor (Business Name): ROBERT T MELIN	Lic. #: 111	Facility ID # (Public Wells):
Address: MELIN WELL DRILLING ASHLAND WI 54806-3825		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity:

1. Well Location

Town of BELL

Fire # (if avail.): 21010

Street Address or Road Name and Number: BLUE BERRY LN RD

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 46.8581 °N -91.1337 °W			Method Code: GCD013
NW NW or Govt Lot #:	Section: 33	Township: 51 N	Range: 6 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of SUMMER CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	128

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOP SOIL	Surface	2
-	-	S	-	SAND	2	32
-	-	C	-	CLAY	32	105
-	N	S	-	SAND (FINE)	105	110
-	A	S	-	SAND (COURSE)	110	128

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC-SDR-17-250PSI F450 EAGLE	Surface	108
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	JOHNSON-15 SLOT-PVC	108	128

9. Static Water Level

_____ ft. above ground surface

10. Pump Test

Pumping level _____ ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HEAVY BENTONITE SLURRY MIXED WITH DRILL CUTTINGS	Surface	108	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
RTM		10-21-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DR		10-21-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary		60	Septic or Holding, or POWTS Tank		50

Comment: FLOWING STATIC WATER LEVEL & PUMP TEST

Created On: 11-14-2017 Updated On: 06-25-2020 Review Status: