Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XX504

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RICHARDS, FRASER	Phone #: (520)465-8896
Mailing Address: 5660 E SHADOW VIEW CT	
City: TUCSON	State: AZ — Zip Code: 85750

County	Co. Permit #	Notification #	Completed
Ashland		6995790601	11-08-2017

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROBERT T MELIN	111	

Address: MELIN WELL DRILLING
ASHLAND WI 54806-3825

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.6

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of LAPOINTE

Fire # (if avail.): NA

Street Address or Road Name and Number
HAGEN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
46.78375 °N -90.68883 °W	GPS008

NE	NW	Section	Township	Range
or Govt Lot #		25	50 N	3 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	42
6	42	100

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation .....
- No / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOP SOIL	Surface	2
-	-	C	-	CLAY	2	8
-	S	N	-	SANDSTONE (SOFT)	8	30
-	H	N	-	SANDSTONE (HARD)	30	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL-20LBS-ASTM-A53B WHEATLAND T&C	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	42	12 S

9. Static Water Level
27 ft. below ground surface

10. Pump Test
Pumping level 37 ft. below surface
Pumping at 6 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
28 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE ON PROPERTY NEW CONST.

13. Constructor / Supervisory Driller	Lic #	Date Signed
RTM		11-13-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DR		11-13-2017

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary		50	Septic or Holding, or POWTS Tank		75

Comment: SEPTIC & BLDG SEWER DISTANCES PROPOSED

Created On: 12-21-2017 Updated On: 02-09-2018 Review Status: