

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XX505		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HABEDANK, NORMAN						Phone # (715)293-0059		1. Well Location				Fire # (if avail.)							
Mailing Address 100 HEIRLOOM AVE APT 103						Town of EILEEN						30110							
City HUDSON						State WI		Zip Code 54016				Street Address or Road Name and Number STATE HWY 137							
County Bayfield		Co. Permit #		Notification # 7035600801		Completed 12-01-2017		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) ROBERT T MELIN				Lic. # 111		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.57155 °N -90.94538 °W				Method Code GPS008					
Address MELIN WELL DRILLING ASHLAND WI 54806-3825				Well Plan Approval # Approval Date (mm-dd-yyyy)		NW NW		Section 12		Township 47 N		Range 5 W							
						or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NOT ENOUGH VOLUME Construction Type Drilled													
3. Well serves 2 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		183		Yes Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				- - I - - - C - - - X - - - C - - - X - - A S -		TOP SOIL CLAY SAND & CLAY MIXED CLAY SAND & CLAY MIXED SAND (COURSE)		Surface 2 25 40 150 170 183					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		___ ft. above ground surface				20 in. above grade					
5		PVC-SDR-17-250PSI F450 EAGLE				Surface		173		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 6 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?									
5		JOHNSON-20 SLOT-PVC				173		183											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement HEAVY BENTONITE SLURRY MIXED WITH DRILL CUTTINGS Surface 173 S														Filled & Sealed Well(s) as needed? No OWNER USING OLD WELL FOR SMALL IRRIGATION PROJECT					
13. Constructor / Supervisory Driller														Lic #		Date Signed			
RTM																12-06-2017			
Drill Rig Operator														Lic or Reg #		Date Signed			
DR																12-06-2017			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary		40	Septic or Holding, or POWTS Tank		50

Comment: FLOWING @ 12 GPM. PER DRILLER ON 061118, OWNER IS KEEPING THE PRE-EXISTING WELL. DRILLER WILL BE SENDING INSPECTION FORM & SAMPLE. EXISTING WELL ASSIGNED PS028.

Created On: 12-21-2017**Updated On:** 08-07-2018**Review Status:**