

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY603		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HINTZ, JASON						Phone # 9035560		1. Well Location				Fire # (if avail.)							
Mailing Address N440 2ND DR						Town of COLOMA						Street Address or Road Name and Number N440 2ND DR							
City COLOMA				State WI		Zip Code 54930													
County Waushara		Co. Permit #		Notification # 6942021701		Completed 09-12-2017		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LARRY D HINTZ						Lic. # 508		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9945 °N -89.57237 °W				Method Code GPS008			
Address LARRY HINTZ WELL DRILLING DELAVAN WI 53115-9610						Well Plan Approval #				NW NE Section Township Range or Govt Lot # 32 18 N 8 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled							
						Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #				Common Well #		Specific Capacity 3.8				3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes									
Hicap Well ? No Hicap Property ? No Hicap Potable ?																			
						4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method										8. Geology									
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock							Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
10 Surface 5			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							- - S -		SAND		Surface 90					
6 5 173										- - X -		SAND & CLAY		90 120					
										- - S -		SAND		120 170					
										- - N -		SANDSTONE		170 173					
6. Casing, Liner, Screen										9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		90 ft. below ground surface				18 in. above grade							
6		BLK STEEL P-E 18.97 A53 SAWHILL				Surface 170		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 94 ft. below surface Pumping at 15 GP M for 12 Hrs. Pumping Method ?											
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ?									
Method										Filled & Sealed Well(s) as needed?									
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement															
CLAY SLURRY		Surface 5		S															
										13. Constructor / Supervisory Driller						Lic #		Date Signed	
										LH								09-14-2017	
										Drill Rig Operator						Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		77	Building Overhang		25
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 10-18-2017

Updated On: 10-18-2017

Review Status: