Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XY604

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHMIEDEN, MIKE & DEB			Phone #
Mailing Address: N6159 EVERGREEN DR			
City: ELKHORN	State: WI	Zip Code: 53121	
County: Walworth	Co. Permit #:	Notification #: 6959250801	Completed: 09-25-2017

Well Constructor (Business Name): LARRY D HINTZ	Lic. #: 508	Facility ID # (Public Wells):	
Address: LARRY HINTZ WELL DRILLING DELAVAN WI 53115-9610		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of LAFAYETTE

Fire # (if avail.):

Street Address or Road Name and Number: N6159 EVERGREEN DR

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 42.71563 °N -88.53725 °W				Method Code: GPS008
SE NW or Govt Lot #:	Section: 18	Township: 3 N	Range: 17 E	

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	74

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit ____in. dia... No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	-	CLAY	Surface	6
-	-	Y	-	SAND & GRAVEL	6	32
-	-	X	-	CLAY & SAND	32	65
-	-	S	-	SAND	65	74

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E 18.97 A53 BLK STEEL SAWHILL	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	15 STAINLESS STEEL	70	74

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	6	S

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 25 GP M for 10 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LH		10-02-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment: SEPTIC/SEWER NOT PRESENT

Created On: 10-18-2017 Updated On: 09-12-2019 Review Status: