

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY604		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner SCHMIEDEN, MIKE & DEB						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address N6159 EVERGREEN DR						Town of LAFAYETTE													
City ELKHORN						State WI		Zip Code 53121				Street Address or Road Name and Number N6159 EVERGREEN DR							
County Walworth		Co. Permit #		Notification # 6959250801		Completed 09-25-2017		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LARRY D HINTZ				Lic. # 508		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.71563 °N -88.53725 °W				Method Code GPS008					
Address LARRY HINTZ WELL DRILLING DELAVAN WI 53115-9610				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NW		Section 18		Township 3 N		Range 17 E					
								or Govt Lot #											
Hicap Permanent Well #				Common Well #		Specific Capacity				2. Well Type New Well									
Hicap Well ? No				Hicap Property ? No		Hicap Potable ?				Reason for replaced or reconstructed well ?									
Private, potable				Heat Exchange ___ # of drillholes		Construction Type Drilled													
3. Well serves 1 # of																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		6		Rotary - Mud Circulation						- - C -		CLAY		Surface		6	
6		6		74		Rotary - Air						- - Y -		SAND & GRAVEL		6		32	
						Rotary - Air & Foam						- - X -		CLAY & SAND		32		65	
						Drill-Through Casing Hammer						- - S -		SAND		65		74	
						Reverse Rotary													
						Yes Cable-tool Bit ___ in. dia...				No									
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				18 in. above grade					
6		P.E 18.97 A53 BLK STEEL SAWHILL				Surface		70		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes					
6		15 STAINLESS STEEL				70		74		Pumping at 25 GP M for 10 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
CLAY SLURRY				Surface		6		S		LH						10-02-2017			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment: SEPTIC/SEWER NOT PRESENT

Created On: 10-18-2017

Updated On: 09-12-2019

Review Status: