

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY605		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner HANSEN, SHANE						Phone # (262)215-0757		1. Well Location				Fire # (if avail.)			
Mailing Address N5839 COBB RD						Town of LAFAYETTE						Street Address or Road Name and Number N5839 COBB RD			
City ELKHORN			State WI		Zip Code 53121		Subdivision Name				Lot #		Block #		
County Walworth		Co. Permit #		Notification # 6989311201		Completed 11-13-2017		Latitude / Longitude in Decimal Degree (DD) 42.7041 °N -88.52897 °W				Method Code GPS008			
Well Constructor (Business Name) LARRY D HINTZ				Lic. # 508		Facility ID # (Public Wells)		NE SE Section Township Range or Govt Lot # 19 3 N 17 E		2. Well Type New Well			of previous unique well # constructed in		
Address LARRY HINTZ WELL DRILLING DELAVAN WI 53115-9610				Well Plan Approval #		Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ?							
Hicap Permanent Well #			Common Well #		Specific Capacity 0.4		Construction Type Drilled								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 12															
6 12 160			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
8. Geology															
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)		Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)	
6 P-E BLK STEEL 18.97 A53 SAWHILL			Surface 157		157 160			- C - - CLAY			Surface 12			12 60	
6 STAINLESS STEEL 15			157 160					- - G - GRAVEL			12 60			60 145	
								- - X - CLAY & SAND			60 145			145 160	
								- - G - GRAVEL			145 160				
6. Casing, Liner, Screen															
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)		9. Static Water Level			11. Well Is				
6 P-E BLK STEEL 18.97 A53 SAWHILL			Surface 157		157 160			3 ft. below ground surface			18 in. above grade				
Dia. (in.)			Screen type, material & slot size			From (ft.) To (ft.)		10. Pump Test			Developed ? Yes				
6 STAINLESS STEEL 15			157 160					Pumping level 40 ft. below surface			Disinfected ? Yes				
								Pumping at 15 GP M for 1 Hrs.			Capped ? Yes				
								Pumping Method ?							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?								
CLAY SLURRY			Surface 20		S		Filled & Sealed Well(s) as needed?								
13. Constructor / Supervisory Driller															
LH			Lic #		Date Signed		01-23-2018								
Drill Rig Operator			Lic or Reg #		Date Signed										

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		20

Comment: SEPTIC/SEWER NOT PRESENT

Created On: 02-19-2018

Updated On: 09-12-2019

Review Status: