Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XY605

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: HANSEN, SHANE	Phone #: (262)215-0757
Mailing Address: N5839 COBB RD	
City: ELKHORN	State: WI — Zip Code: 53121
County: Walworth	Co. Permit #:
Notification #: 6989311201	Completed: 11-13-2017
Well Constructor (Business Name): LARRY D HINTZ	Lic. #: 508
Facility ID # (Public Wells):	
Address: LARRY HINTZ WELL DRILLING, DELAVAN WI 53115-9610	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.4	

1. Well Location

Town of LAFAYETTE			Fire # (if avail.)
Street Address or Road Name and Number: N5839 COBB RD			
Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): 42.7041 °N -88.52897 °W			Method Code: GPS008
NE SE or Govt Lot #	Section: 19	Township: 3 N	Range: 17 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	12
6	12	160

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit ____in. dia... — No
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	C	-	-	CLAY	Surface	12
-	-	G	-	GRAVEL	12	60
-	-	X	-	CLAY & SAND	60	145
-	-	G	-	GRAVEL	145	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P-E BLK STEEL 18.97 A53 SAWHILL	Surface	157
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL 15	157	160

9. Static Water Level
3 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LH		01-23-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		20

Comment: SEPTIC/SEWER NOT PRESENT

Created On: 02-19-2018 Updated On: 09-12-2019 Review Status: