

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY606		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner ALBRECHT, DALE					Phone #			1. Well Location				Fire # (if avail.)									
Mailing Address ZIMMERMAN RD					Town of TROY							Street Address or Road Name and Number ZIMMERMAN RD									
City EAST TROY			State WI		Zip Code 53120																
County Walworth		Co. Permit #		Notification # 7035567701			Completed 12-04-2017		Subdivision Name			Lot #		Block #							
Well Constructor (Business Name) LARRY D HINTZ				Lic. # 508		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.79518 °N -88.53108 °W				Method Code GPS008							
Address LARRY HINTZ WELL DRILLING DELAVAN WI 53115-9610				Well Plan Approval #				NE NE Section Township Range or Govt Lot # 19 4 N 17 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #			Common Well #		Specific Capacity																
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ?																
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		5		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Yes Cable-tool Bit ___ in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				- - X -		CLAY & SAND		Surface		12					
6		5		50						- - S -		SAND		12		62					
										- - C -		CLAY		32		40					
										- - G -		GRAVEL		40		50					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		21 ft. below ground surface				18 in. above grade							
6		P-E 18.97 A53 SAWHILL				Surface		47		10. Pump Test Pumping level 21 ft. below surface Pumping at 20 GP M for 10 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
6		15 STAINLESS STEEL				47		50													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?									
Method												Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
CLAY SLURRY				Surface		5		S													
												13. Constructor / Supervisory Driller				Lic #		Date Signed			
												LH						01-23-2018			
												Drill Rig Operator						Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment: SEPTIC/SEWER NOT PRESENT

Created On: 02-06-2018

Updated On: 03-23-2018

Review Status: