

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY607		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner GALLAGHER, ERIC						Phone # (262)749-1180		1. Well Location				Fire # (if avail.)			
Mailing Address N1218 PETERS RD						Town of SHARON						N1218			
City SHARON						State WI		Zip Code 53585				Street Address or Road Name and Number PETERS RD			
County Walworth		Co. Permit #		Notification # 7106660701		Completed 05-03-2018		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) HINTZ, LARRY D				Lic. # 508		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.5332 °N -88.7067 °W				Method Code SCR002	
Address LARRY HINTZ WELL DRILLING N5273 CTY TRK M DELAVAN WI 53115-9610				Well Plan Approval #				SW NE Section Township Range or Govt Lot # 22 1 N 15 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity		Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
10		Surface		12		No Rotary - Mud Circulation				No					
6		12		136		No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
C		C-CLAY						Surface		12					
G		G-GRAVEL/STONES						12		62					
Z		Z-CLAY & GRAVEL						62		90					
S		S-SAND						90		136					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		PE 18.97 BLK A53 PIPE				Surface		133							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		STAINLESS STEEL 15				133		136							
7. Grout or Other Sealing Material															
Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement CLAY SLURRY Surface 12															
9. Static Water Level 70 ft. below ground surface															
10. Pump Test Pumping level 70 ft. below surface Pumping at 15 GP M for 12 Hrs. Pumping Method ? Airlift															
11. Well Is 18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
LH				508		05-03-2018									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: WELL IS 12' AWAY FROM BLDG OVERHANG. SEPTIC/SEWER NOT PRESENT.

Created On: 11-28-2018

Updated On: 11-29-2018

Review Status: APPROVED