Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XY607

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GALLAGHER, ERIC	Phone #: (262)749-1180
Mailing Address: N1218 PETERS RD	
City: SHARON	State: WI — Zip Code: 53585
County: Walworth	Co. Permit #:
Notification #: 7106660701	Completed: 05-03-2018
Well Constructor (Business Name): HINTZ, LARRY D	Lic. #: 508
Facility ID # (Public Wells):	
Address: LARRY HINTZ WELL DRILLING N5273 CTY TRK M DELAVAN WI 53115-9610	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity:	

1. Well Location

Town of SHARON	Fire # (if avail.): N1218
Street Address or Road Name and Number: PETERS RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.5332 °N -88.7067 °W	Method Code: SCR002
SW NE or Govt Lot #:	Section: 22 — Township: 1 N — Range: 15 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	12
6	12	136

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	C-CLAY	Surface	12
G	G-GRAVEL/STONES	12	62
Z	Z-CLAY & GRAVEL	62	90
S	S-SAND	90	136

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE 18.97 BLK A53 PIPE	Surface	133
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	STAINLESS STEEL 15	133	136

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	12	

9. Static Water Level

70 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 15 GP M for 12 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
LH	508	05-03-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: WELL IS 12' AWAY FROM BLDG OVERHANG. SEPTIC/SEWER NOT PRESENT.

Created On: 11-28-2018 Updated On: 11-29-2018 Review Status: APPROVED