Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XY721

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: KRESS, JON	Phone #: (715)339-3600
Mailing Address: N8861 GOLF COURSE RD	
City: PHILLIPS	State: WI — Zip Code: 54555
County: Price	Co. Permit #:
Notification #: 6941992001	Completed: 09-05-2017
Well Constructor (Business Name): DONALD F KARNOSH	Lic. #: 660
Facility ID # (Public Wells):	
Address: KARNOSH WELL DRILLING, PHILLIPS WI 54555	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.1	

1. Well Location

Town of ELK	Fire # (if avail.): W7573
Street Address or Road Name and Number: W7573 GARDEN LN	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.69357 °N -90.44537 °W	Method Code: GPS008
NE NW or Govt Lot #:	Section: 13 — Township: 37 N — Range: 1 W

2. Well Type Replacement
of previous unique well # XY722 constructed in 2017
Reason for replaced or reconstructed well ?: NO WATER
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	25

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	G	-	GRAVEL-RED	Surface	8
R	-	C	P	CLAY-HARDPAN-RED	8	20
R	-	G	-	GRAVEL-RED	20	25

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A-53 MARUICHI-LEAZITT P.E	Surface	25
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface		1 S

9. Static Water Level
13 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		09-05-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		25
			Septic or Holding, or POWTS Tank		80

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	07/31/2025	6 BAGS OF BENTONITE	REPLACED BY XY721

Created On: 10-18-2017 Updated On: 08-19-2025 Review Status: