

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY721		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KRESS, JON				Phone # (715)339-3600		1. Well Location				Fire # (if avail.)	
Mailing Address N8861 GOLF COURSE RD						Town of ELK				W7573	
City PHILLIPS				State WI Zip Code 54555		Street Address or Road Name and Number W7573 GARDEN LN					
County Price		Co. Permit #		Notification # 6941992001		Completed 09-05-2017		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) DONALD F KARNOSH				Lic. # 660		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.69357 °N -90.44537 °W		Method Code GPS008	
Address KARNOSH WELL DRILLING PHILLIPS WI 54555				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 13 37 N 1 W		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 2.1		Reason for replaced or reconstructed well ? NO WATER			
3. Well serves 1 # of Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
6		Surface		25		No Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... R - G - GRAVEL-RED R - C P CLAY-HARDPAN-RED R - G - GRAVEL-RED	
										From (ft.) To (ft.) Surface 8 8 20 20 25	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
6		STEEL 18.97 A-53 MARUICHI-LEAZITT P.E				Surface		25		18 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
BENTONITE				Surface				1 S			
9. Static Water Level											
13 ft. below ground surface											
10. Pump Test											
Pumping level 20 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
DK				Lic #		Date Signed		09-05-2017			
Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		25
			Septic or Holding, or POWTS Tank		80

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	07/31/2025	6 BAGS OF BENTONITE	REPLACED BY XY721

Created On: 10-18-2017

Updated On: 08-19-2025

Review Status: