Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XY723

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHMIDT, JOSH	Phone #: (715)339-4234
Mailing Address: W7397 MORNINGSIDE DR	
City: PHILLIPS	State: WI — Zip Code: 54555

County	Co. Permit #	Notification #	Completed
Price		6941994901	09-21-2017

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DONALD F KARNOSH	660	

Address: KARNOSH WELL DRILLING, PHILLIPS WI 54555

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		7.5

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ELK	Fire # (if avail.) W7397

Street Address or Road Name and Number: W7397 MORNINGSIDE DR

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.70295 °N -90.43212 °W	GPS008

SE NE or Govt Lot #	Section	Township	Range
	12	37 N	1 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	74

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R - G C	RED GRAVEL & CLAY	Surface	10
R - Z P	RED HARDPAN, CLAY & BOULDERS	10	62
G - C -	GRAY CLAY	62	70
R - Y -	RED SAND & GRAVEL	70	74

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LB A-53 MARUICHI-LEAVITT P.E.	Surface	74
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
26 ft. below ground surface

10. Pump Test
Pumping level 28 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		09-26-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100
Building Overhang		16
Clearwater Sump		75
Foundation Drain to Clearwater		20
Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 10-18-2017 Updated On: 06-19-2020 Review Status: