

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY723		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner SCHMIDT, JOSH						Phone # (715)339-4234		1. Well Location				Fire # (if avail.)									
Mailing Address W7397 MORNINGSIDE DR						Town of ELK						W7397									
City PHILLIPS						State WI		Zip Code 54555				Street Address or Road Name and Number W7397 MORNINGSIDE DR									
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #							
Price				6941994901		09-21-2017															
Well Constructor (Business Name) DONALD F KARNOSH				Lic. # 660		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.70295 °N -90.43212 °W				Method Code GPS008							
Address KARNOSH WELL DRILLING PHILLIPS WI 54555				Well Plan Approval #				SE NE		Section 12		Township 37 N		Range 1 W							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 7.5				2. Well Type New Well				of previous unique well #		constructed in					
Reason for replaced or reconstructed well ?																					
3. Well serves 1 # of				Hicap Well ? No				Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		74		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								R - G C		RED GRAVEL & CLAY		Surface		10	
														R - Z P		RED HARDPAN, CLAY & BOULDERS		10		62	
														G - C -		GRAY CLAY		62		70	
														R - Y -		RED SAND & GRAVEL		70		74	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		26 ft. below ground surface				20 in. above grade							
6		STEEL 18.97 LB A-53 MARUICHI-LEAVITT P.E.				Surface		74		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 28 ft. below surface				Disinfected ? Yes							
										Pumping at 15 GP M for 2 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method MOUNDED														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
GRANULAR BENTONITE				Surface				1 S													
13. Constructor / Supervisory Driller								Lic #		Date Signed											
DK										09-26-2017											
Drill Rig Operator								Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Clearwater Sump		75
			Foundation Drain to Clearwater		20
Building Overhang		16	Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 10-18-2017

Updated On: 06-19-2020

Review Status: