

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XY724		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MAKOVSKY, TROY						Phone # (715)820-0297		1. Well Location				Fire # (if avail.)			
Mailing Address 515 STORMS RD						City of PHILLIPS						515			
City PHILLIPS						State WI		Zip Code 54555				Street Address or Road Name and Number 515 STORMS RD			
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #	
Price				6968059601		10-05-2017									
Well Constructor (Business Name) DONALD F KARNOSH				Lic. # 660		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.68657 °N -90.41065 °W				Method Code GPS008			
Address KARNOSH WELL DRILLING PHILLIPS WI 54555				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 18 37 N 1 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? REPLACED OLD DUG WELL-POOR WATER							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.9		Hicap Well ? No		Construction Type Drilled							
				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
6		Surface		55		No Rotary - Mud Circulation		No		R - Z P RED GRAVEL & HARDPAN CLAY-ROCKS					
						No Rotary - Air		No		G - P C GRAY HARDPAN-CLAY-BOULDERS					
						No Rotary - Air & Foam		No		- - S U MUDDY SAND					
						No Drill-Through Casing Hammer				- - G - GRAVEL					
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...		No							
						No Dual Rotary		No							
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		STEEL 18.97 LB A-53 MARUICHI-LEAZITT P.E.				Surface		55		13 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
										18 in. above grade					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test					
GRANULAR BENTONITE				Surface				1 S		Developed ? Yes					
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? TO BE DONE LATER Yes															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
DK										10-27-2017					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Building Overhang		6
			Septic or Holding, or POWTS Tank	>	50

Comment: OWNER SENT E-MAIL 041618 TO INDICATE WILL BE F&S WELL. APPLIED FOR PRICE COUNTY GRANT.

Created On: 01-09-2018

Updated On: 06-19-2020

Review Status: