Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XY724

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MAKOVSKY, TROY	Phone #: (715)820-0297
Mailing Address: 515 STORMS RD	
City: PHILLIPS	State: WI — Zip Code: 54555
County: Price	Co. Permit #:
Notification #: 6968059601	Completed: 10-05-2017
Well Constructor (Business Name): DONALD F KARNOSH	Lic. #: 660
Facility ID # (Public Wells):	
Address: KARNOSH WELL DRILLING, PHILLIPS WI 54555	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.9	

1. Well Location

City of PHILLIPS	Fire # (if avail.): 515
Street Address or Road Name and Number: 515 STORMS RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.68657 °N -90.41065 °W	Method Code: GPS008
NW SW or Govt Lot #:	Section: 18 — Township: 37 N — Range: 1 E

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: REPLACED OLD DUG WELL-POOR WATER
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	55

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	-	Z	P	RED GRAVEL & HARDPAN CLAY-ROCKS	Surface	35
G	-	P	C	GRAY HARDPAN-CLAY-BOULDERS	35	45
-	-	S	U	MUDDY SAND	45	50
-	-	G	-	GRAVEL	50	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 LB A-53 MARUICHI-LEAZITT P.E.	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level
13 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? Yes
TO BE DONE LATER

13. Constructor / Supervisory Driller	Lic #	Date Signed
DK		10-27-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Building Overhang		6
			Septic or Holding, or POWTS Tank	>	50

Comment: OWNER SENT E-MAIL 041618 TO INDICATE WILL BE F&S WELL. APPLIED FOR PRICE COUNTY GRANT.

Created On: 01-09-2018 Updated On: 06-19-2020 Review Status: