

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XZ642		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner JOHNSON BROTHERS FARM						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 111 AKRON LN						Town of LEOLA						111			
City PLAINFIELD						State WI		Zip Code 54966				Street Address or Road Name and Number AKRON LN			
County Adams		Co. Permit #		Notification # 7037146501		Completed 01-09-2018		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) TERRY FARAGO				Lic. # 41		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.233 °N -89.60007 °W				Method Code GPS008	
Address N6079 8TH AVE PLAINFIELD WI 54966-9757				Well Plan Approval #		NE SE		Section 1		Township 20 N		Range 7 E			
Hicap Permanent Well #				Common Well #		Specific Capacity 20				2. Well Type Replacement of previous unique well # constructed in					
Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? MILK MARKETING CODES				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		76		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes - - S - SAND					
										From (ft.) Surface To (ft.) 76					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
6		EXL TUBE A53 6.625 X .280 WALL WELDED TOGETHER WEIGHT - 1,369.5				Surface		73		Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) Surface To (ft.) 76					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		9. Static Water Level					
6		#12 S&S				73		76		5 ft. below ground surface					
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement BENT ALONG CASING Surface										10. Pump Test Pumping level 6 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?					
11. Well Is 30 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes WAIT TO DIG IT IN															
13. Constructor / Supervisory Driller										Lic #		Date Signed			
TPF												01-11-2018			
Drill Rig Operator										Lic or Reg #		Date Signed			
CF												01-11-2018			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		105
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 02-06-2018

Updated On: 05-03-2018

Review Status: