

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XZ644		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner HOSLER, MATTHEW						Phone # (608)385-8028		1. Well Location				Fire # (if avail.)		
Mailing Address 1338 DYKE AVE						Town of ADAMS						1330		
City ADAMS						State WI		Zip Code 53910				Street Address or Road Name and Number DYKE AVE		
County Adams		Co. Permit #		Notification # 7050794501		Completed 01-31-2018		Subdivision Name HIDE A WAY ACS			Lot # 4		Block #	
Well Constructor (Business Name) TERRY FARAGO				Lic. # 41		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.90598 °N -89.82353 °W				Method Code GPS008		
Address N6079 8TH AVE PLAINFIELD WI 54966-9757				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NW NE Section Township Range or Govt Lot # 31 17 N 6 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled				
Hicap Permanent Well #		Common Well #		Specific Capacity 9										
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
6		Surface		94		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam <u>Yes</u> Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
- - S -				SAND				Surface		35				
- - C -				CLAY				35		54				
- N X -				CLAY & FINE SAND				54		84				
- - S -				SAND				84		94				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level				
6		IPSCO A53 6.625 X .280 WALL WELDED TOGETHER WEIGHT - 1726.27				Surface		91		21 ft. below ground surface				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test				
6		#7 ALLOY S&S				91		94		Pumping level 23 ft. below surface Pumping at 18 GP M for 1 Hrs. Pumping Method ?				
7. Grout or Other Sealing Material														
Method														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		11. Well Is				
BENT ALONG CASING				Surface						30 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes				
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? Yes														
13. Constructor / Supervisory Driller														
TPF				Lic #				Date Signed 02-06-2018						
Drill Rig Operator				Lic or Reg #				Date Signed 02-06-2018						
CF														

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		121	Building Overhang		51
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 02-19-2018

Updated On: 05-04-2020

Review Status: