Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XZ644

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOSLER, MATTHEW	Phone #: (608)385-8028
Mailing Address: 1338 DYKE AVE	
City: ADAMS	State: WI — Zip Code: 53910
County: Adams	Co. Permit #:
Notification #: 7050794501	Completed: 01-31-2018
Well Constructor (Business Name): TERRY FARAGO	Lic. #: 41
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: N6079 8TH AVE PLAINFIELD WI 54966-9757	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 9	

1. Well Location

Town of ADAMS	Fire # (if avail.): 1330
Street Address or Road Name and Number: DYKE AVE	
Subdivision Name: HIDE A WAY ACS	Lot #: 4 — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.90598 °N -89.82353 °W	Method Code: GPS008

NW	NE	Section	Township	Range
or Govt Lot #		31	17 N	6 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	94

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Yes — Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	S	-	SAND	Surface	35
-	-	C	-	CLAY	35	54
-	N	X	-	CLAY & FINE SAND	54	84
-	-	S	-	SAND	84	94

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A53 6.625 X .280 WALL WELDED TOGETHER WEIGHT - 1726.27	Surface	91
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#7 ALLOY S&S	91	94

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENT ALONG CASING	Surface		

9. Static Water Level

21 ft. below ground surface

10. Pump Test

Pumping level 23 ft. below surface

Pumping at 18 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TPF		02-06-2018
Drill Rig Operator	Lic or Reg #	Date Signed
CF		02-06-2018

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		121

Type	Qualifier	Distance
Building Overhang		51
Septic or Holding, or POWTS Tank		75

Comment:

Created On: 02-19-2018 Updated On: 05-04-2020 Review Status: