

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				XZ864		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LAHTI, JOHN						Phone # (715)292-1879		1. Well Location				Fire # (if avail.)			
Mailing Address PO BOX 491						Town of TRIPP						7999			
City IRON RIVER						State WI		Zip Code 54847				Street Address or Road Name and Number			
County Bayfield						Co. Permit #		Notification # 6964200001		Completed 09-30-2017		7999 CHEESE FACTORY RD			
Well Constructor (Business Name) WAYNE HOLLY						Lic. # 7218		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.60422 °N -91.40757 °W				Method Code GPS008	
Address WAYNE HOLLY WELL DRILLING IRON RIVER WI 54847						Well Plan Approval #		NE NE		Section 31		Township 48 N		Range 8 W	
						Approval Date (mm-dd-yyyy)		or Govt Lot #		31		48 N		8 W	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.3				2. Well Type New Well					
Reason for replaced or reconstructed well ?						of previous unique well # constructed in									
3. Well serves 1 # of Private, potable						Hicap Well ? No		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes						Hicap Property ? No		Construction Type Drilled							
Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock									
8		Surface		6											
4		6		60											
Rotary - Mud Circulation															
Rotary - Air															
Rotary - Air & Foam															
Drill-Through Casing Hammer															
Reverse Rotary															
Yes Cable-tool Bit ___ in. dia...						No									
Dual Rotary															
Temp. Outer Casing ___ in. dia															
Removed? ___ depth ft. (If NO explain on back side)															
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
- - C S				SANDY CLAY				Surface		40					
- - P -				HARDPAN				40		57					
- W S -				WATER & SAND				57		60					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4.5		OD 4IN ID T&C ASTM A-53-B IPSCO				Surface		57							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
2		10 SLOT SCREEN 4/2 KPAC				57		60							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
CASING SEAL				Surface		6		S							
9. Static Water Level															
13 ft. above ground surface															
10. Pump Test															
Pumping level 20 ft. below surface															
Pumping at 10 GP M for 8 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
WH								10-19-2017							
Drill Rig Operator															
Lic or Reg #				Date Signed											
RH								10-19-2017							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		48	Septic or Holding, or POWTS Tank		95

Comment: FLOW

Created On: 12-21-2017

Updated On: 02-09-2023

Review Status: