Well Construction Report
WISCONSIN UNIQUE WELL NUMBER XZ887

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KAROL, KEN	Phone #: (715)882-4341
Mailing Address: N2904 HWY 55	
City: WHITE LAKE	State: WI Zip Code: 54491
County: Langlade	Co. Permit #:
Notification #: 6611565701	Completed: 11-09-2016
Well Constructor (Business Name): EDWARD J DREWS	Lic. #: 327
Facility ID # (Public Wells):	
Address: DREWS WELL DRLG RINGLE WI 54471	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.8	

1. Well Location

Town of WOLF RIVER

Fire # (if avail.):

Street Address or Road Name and Number: W2005 HWY M

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 45.12394 °N -88.74051 °W

Method Code: SCR002

NW SW or Govt Lot #: | Section: 34 | Township: 31 N | Range: 14 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of SHOP

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?:

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	78

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Y	-	SAND & GRAVEL	Surface	72
-	-	G	-	GRAVEL	72	78

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARUICHI LEAVITT A53 18.97 WELDED	Surface	78
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

54 ft. below ground surface

10. Pump Test

Pumping level 71 ft. below surface

Pumping at 30 GP M for 1 Hrs.

Pumping Method ?:

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJD		11-13-2016
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		8

Comment:

Created On: 12-02-2016 Updated On: 12-02-2016 Review Status: