

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YA098		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner BROWN, BILL					Phone # (414)254-0470		1. Well Location				Fire # (if avail.)	
Mailing Address 715 MILWAUKEE ST							Town of HERMAN				6227	
City DELAFIELD					State WI		Zip Code 53018				Street Address or Road Name and Number	
County Dodge					Co. Permit #		Notification # 6881635201				Completed 07-18-2017	
Subdivision Name					Lot #		Block #					
Well Constructor (Business Name) RICHARD L UMLAND					Lic. # 89		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4186 °N -88.4806 °W	
Address RICKS WELL & PUMP SERVICE MAYVILLE WI 53050					Well Plan Approval #		SE SE Section Township Range or Govt Lot # 17 11 N 17 E				Method Code GCD013	
Approval Date (mm-dd-yyyy)					Specific Capacity 2		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #					Common Well #		Reason for replaced or reconstructed well ?					
3. Well serves 1 # of SHOP					Hicap Well ? No		Construction Type Drilled					
Private, potable					Hicap Property ? No							
Heat Exchange ___ # of drillholes					Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock			
8		Surface		50		<u>Yes</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>Yes</u> Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						
6		50		98								
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
G - P -		GRAY HARDPAN				Surface		50				
- - L -		LIMESTONE				50		98				
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)				
6		BLACK P.E. 18.97LBS/FT A-53 G-B WHEATLAND STEEL				Surface		51				
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)				
7. Grout or Other Sealing Material												
Method												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement						
DRILLING MUD		Surface		50		S						
9. Static Water Level												
30 ft. below ground surface												
10. Pump Test												
Pumping level 40 ft. below surface												
Pumping at 20 GP M for 1 Hrs.												
Pumping Method ?												
11. Well Is												
12 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ?												
Filled & Sealed Well(s) as needed?												
13. Constructor / Supervisory Driller												
Lic #		Date Signed										
RU		07-22-2017										
Drill Rig Operator		Lic or Reg #		Date Signed								
KS												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		9	Downspout/Yard Hydrant		10

Comment:

Created On: 08-28-2017

Updated On: 10-01-2019

Review Status: