Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YA098

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BROWN, BILL			Phone #: (414)254-0470
Mailing Address: 715 MILWAUKEE ST			
City: DELAFIELD	State: WI	Zip Code: 53018	
County: Dodge	Co. Permit #:	Notification #: 6881635201	Completed: 07-18-2017

1. Well Location

Town of HERMAN

Fire # (if avail.): 6227

Street Address or Road Name and Number: 6227 PIERCE RD

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): RICHARD L UMLAND	Lic. #: 89	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 43.4186 °N -88.4806 °W
Address: RICKS WELL & PUMP SERVICE MAYVILLE WI 53050		Well Plan Approval #	Method Code: GCD013
		Approval Date (mm-dd-yyyy)	

SE	SE	Section	Township	Range
or Govt Lot #		17	11 N	17 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well # | Common Well # | Specific Capacity: 2

3. Well serves 1 # of SHOP

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	50
6	50	98

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation .....
- No / Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G - P -	GRAY HARDPAN	Surface	50
- - L -	LIMESTONE	50	98

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK P.E. 18.97LBS/FT A-53 G-B WHEATLAND STEEL	Surface	51
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	50	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RU		07-22-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		9	Downspout/Yard Hydrant		10

Comment:

Created On: 08-28-2017 Updated On: 10-01-2019 Review Status: