Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YA107

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MARK BOHN CARPENTRY	Phone #: (262)224-0161
Mailing Address: 4812 BERKSHIRE CT	
City: WEST BEND	State: WI — Zip Code: 53095
County: Washington	Co. Permit #:
Notification #: 6974757501	Completed: 10-19-2017
Well Constructor (Business Name): KARL I STENERSON	Lic. #: 368
Facility ID # (Public Wells):	
Address: STENERSON WELL DRILLING, HORICON WI 53032	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.5	

1. Well Location

Town of ADDISON	Fire # (if avail.): 6548
Street Address or Road Name and Number: 6548 HWY R	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.37283 °N -88.36295 °W	Method Code: GPS008
SE SE or Govt Lot #:	Section: 32 — Township: 11 N — Range: 18 E

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?: NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	203
6	203	245

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes — Rotary - Mud Circulation ..... — No
- No — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	CLAY & STONES	Surface	106
-	-	G	C	GRAVEL & CLAY	106	111
-	-	C	G	CLAY & STONES	111	203
-	-	L	H	LIMESTONE W/LAYERS OF SHALE	203	245

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW 18.97 LB A-53 GB P.E W-SHOE WHEATLAND	Surface	203
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
70 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTING	Surface	203	S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KS		10-20-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120
Building Overhang		15
Downspout/Yard Hydrant		20
Foundation Drain to Clearwater		15
Sewer - Building Sanitary		80
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 01-09-2018 Updated On: 01-09-2018 Review Status: