Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YA108

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRUCH, BILL			Phone #: (414)406-4139
Mailing Address: 663 COLGATE RD			
City: COLGATE	State: WI	Zip Code: 53017	
County: Waukesha	Co. Permit #:	Notification #: 6984896001	Completed: 11-16-2017

Well Constructor (Business Name): KARL I STENERSON	Lic. #: 368	Facility ID # (Public Wells):	
Address: STENERSON WELL DRILLING, HORICON WI 53032		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.5	

3. Well serves 1 # of SHOP
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of LISBON

Fire # (if avail.): 22319

Street Address or Road Name and Number: W22319 GOOD HOPE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)			Method Code
43.14608 °N	-88.19102 °W		GPS008

NE NW or Govt Lot #	Section: 24	Township: 8 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
SHOP

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	105
6	105	151

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation ..... — No
- No / Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
- - C -	CLAY	Surface	4
- - L -	LIMESTONE	4	150

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW 18.97 LB STEEL A-53 GR. B P.E.	Surface	105
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	105	36 S

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KS		12-07-2017
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		60
Building Overhang		10	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-09-2018 Updated On: 01-09-2018 Review Status: