

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YA111		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MARK BOHN CARPENTRY LLC						Phone # (262)224-0161		1. Well Location				Fire # (if avail.)							
Mailing Address 4812 BERKSHIRE CT						Town of ERIN						879							
City WEST BEND						State WI		Zip Code 53095				Street Address or Road Name and Number							
County Washington						Co. Permit #		Notification # 7073486301				Completed 01-25-2018							
Subdivision Name EMERALD HLS						Lot #		Block #											
Well Constructor (Business Name) KARL I STENERSON						Lic. # 368		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2219 °N -88.41602 °W							
Address STENERSON WELL DRILLING HORICON WI 53032						Well Plan Approval #		NW NW		Section 30		Township 9 N							
Hicap Permanent Well #						Common Well #		Specific Capacity 0.8				Range 18 E							
3. Well serves 1 # of Private, potable						Hicap Well ? No		2. Well Type New Well											
Heat Exchange ___ # of drillholes						Hicap Property ? No		of previous unique well # constructed in											
Reason for replaced or reconstructed well ?						Hicap Potable ?		NEW HOME											
4. Potential Contamination Sources - ON REVERSE SIDE						Construction Type Drilled													
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
8		Surface		92		Yes Rotary - Mud Circulation No Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						- - C G		CLAY & STONES		Surface		23	
												- - C S		SANDY CLAY		23		69	
												- - C G		CLAY & GRAVEL		69		90	
												- - Y -		GRAVEL & SAND		90		92	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				18 in. above grade					
6		NEW 18.97 LB STEEL A53 GR B. P.E. W/SHOE WHEATLAND				Surface		92		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 60 ft. below surface Pumping at 20 GP M for 6 Hrs. Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement				13. Constructor / Supervisory Driller				Lic #		Date Signed	
DRILLING MUD & CUTTING				Surface		92		S				KS						03-12-2018	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Foundation Drain to Clearwater		15
Building Overhang		15	Sewer - Building Sanitary		20
			Septic or Holding, or POWTS Tank		70

Comment:

Created On: 03-27-2018

Updated On: 07-08-2019

Review Status: