Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YA111

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARK BOHN CARPENTRY LLC	Phone #: (262)224-0161
Mailing Address: 4812 BERKSHIRE CT	
City: WEST BEND	State: WI — Zip Code: 53095

County	Co. Permit #	Notification #	Completed
Washington		7073486301	01-25-2018

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
KARL I STENERSON	368	

Address: STENERSON WELL DRILLING, HORICON WI 53032

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.8

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of ERIN

Fire # (if avail.): 879

Street Address or Road Name and Number: 879 SKIDBOREEN WAY

Subdivision Name	Lot #	Block #
EMERALD HLS		

Latitude / Longitude in Decimal Degree (DD)				Method Code
43.2219 °N	-88.41602 °W			GPS008

NW NW or Govt Lot #	Section	Township	Range
	30	9 N	18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	92

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation ..... — No
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	C	G	CLAY & STONES	Surface	23
-	-	C	S	SANDY CLAY	23	69
-	-	C	G	CLAY & GRAVEL	69	90
-	-	Y	-	GRAVEL & SAND	90	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW 18.97 LB STEEL A53 GR B. P.E. W/SHOE WHEATLAND	Surface	92
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 20 GP M for 6 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTING	Surface	92	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KS		03-12-2018
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Overhang		15

Type	Qualifier	Distance
Foundation Drain to Clearwater		15
Sewer - Building Sanitary		20
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 03-27-2018 Updated On: 07-08-2019 Review Status: