

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YA112		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner MAJESTIC DESIGN & BUILD						Phone # (262)287-7976		1. Well Location				Fire # (if avail.)							
Mailing Address 7225 SUSAN DR						Town of LEBANON						3240							
City WEST BEND						State WI		Zip Code 53095				Street Address or Road Name and Number							
W3240 HWY O						Subdivision Name				Lot #		Block #							
County Dodge		Co. Permit #		Notification # 7073487501		Completed 02-27-2018		Latitude / Longitude in Decimal Degree (DD)				Method Code							
Well Constructor (Business Name) KARL I STENERSON				Lic. # 368		Facility ID # (Public Wells)				43.22137 °N -88.5529 °W		GPS008							
Address STENERSON WELL DRILLING HORICON WI 53032				Well Plan Approval #		NW NW		Section 25		Township 9 N		Range 16 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		2. Well Type New Well				of previous unique well # constructed in									
Reason for replaced or reconstructed well ?				NEW HOME				Construction Type Drilled											
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No				Hicap Potable ?									
Heat Exchange ___ # of drillholes																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		106		Yes Rotary - Mud Circulation		No		- - Z S		SANDY CLAY & STONES		Surface		38			
6		106		112		No Rotary - Air		Yes		- - C -		CLAY		38		106			
						Rotary - Air & Foam				- - L -		LIMESTONE		106		112			
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												8. Geology							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		35 ft. below ground surface				11. Well Is					
6		NEW 18.97 LB STEEL A53 GR B PE W/SHOE WHEATLAND				Surface		106		10. Pump Test				14 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 45 ft. below surface				Developed ? Yes					
										Pumping at 15 GP M for 2 Hrs.				Disinfected ? Yes					
										Pumping Method ?				Capped ? Yes					
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?				Yes			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
DRILLING MUD & CUTTING		Surface		106		S													
13. Constructor / Supervisory Driller												Lic #		Date Signed					
KS														03-12-2018					
Drill Rig Operator												Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Downspout/Yard Hydrant		20
Building Overhang		14	Foundation Drain to Clearwater		14
Clearwater Sump		40	Sewer - Building Sanitary		45
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-27-2018

Updated On: 03-27-2018

Review Status: