Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YA112

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAJESTIC DESIGN & BUILD	Phone #: (262)287-7976
Mailing Address: 7225 SUSAN DR	
City: WEST BEND	State: WI — Zip Code: 53095
County: Dodge	Co. Permit #:
Notification #: 7073487501	Completed: 02-27-2018
Well Constructor (Business Name): KARL I STENERSON	Lic. #: 368
Facility ID # (Public Wells):	
Address: STENERSON WELL DRILLING, HORICON WI 53032	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.5	

1. Well Location

Town of LEBANON	Fire # (if avail.): 3240
Street Address or Road Name and Number: W3240 HWY O	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.22137 °N -88.5529 °W	Method Code: GPS008
NW NW or Govt Lot #	Section: 25 — Township: 9 N — Range: 16 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	106
6	106	112

Upper Enlarged Drillhole / Lower Open Bedrock

- Yes / No — Rotary - Mud Circulation ..... — No
- No / Yes — Rotary - Air ..... — Yes
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	Z	S	SANDY CLAY & STONES	Surface	38
-	-	C	-	CLAY	38	106
-	-	L	-	LIMESTONE	106	112

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW 18.97 LB STEEL A53 GR B PE W/SHOE WHEATLAND	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTING	Surface	106	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KS		03-12-2018
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Downspout/Yard Hydrant		20
Building Overhang		14	Foundation Drain to Clearwater		14
Clearwater Sump		40	Sewer - Building Sanitary		45
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-27-2018 Updated On: 03-27-2018 Review Status: