

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				YA113		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KANAS, TOM						Phone # (262)388-5798		1. Well Location				Fire # (if avail.)							
Mailing Address N9301 N POLE RD						Town of HUBBARD						N6251							
City THERESA						State WI		Zip Code 53091				Street Address or Road Name and Number N6251 E NEDA RD							
County Dodge		Co. Permit #		Notification # 6897576701		Completed 08-02-2017		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) RICHARD L UMLAND				Lic. # 89		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.41895 °N -88.53542 °W									
Address RICKS WELL & PUMP SERVICE MAYVILLE WI 53050				Well Plan Approval #		SE SW		Section 13		Township 11 N		Method Code GPS008							
				Approval Date (mm-dd-yyyy)		Range 16 E													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		2. Well Type New Well				of previous unique well # constructed in									
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?				Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Property ? No															
				Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
8		Surface		53		<u>Yes</u> Rotary - Mud Circulation				<u>No</u>		T - P -		BROWN HARD PAN		Surface 9			
6		53		67		<u>No</u> Rotary - Air				<u>Yes</u>		G - C -		GRAY CLAY		9 53			
						Rotary - Air & Foam						G - H -		DARK GRAY SHALE		53 67			
						Drill-Through Casing Hammer													
						Reverse Rotary													
						Cable-tool Bit ___ in. dia...													
						Dual Rotary													
						Temp. Outer Casing ___ in. dia													
						Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		30 ft. below ground surface				14 in. above grade							
6		BLACK P.E. 18.97 LBS/FT. A-53 G-B WHEATLAND STEEL				Surface 54		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 45 ft. below surface				Disinfected ? Yes							
								Pumping at 10 GP M for 0.5 Hrs.				Capped ? Yes							
								Pumping Method ?											
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
DRILLING MUD				Surface		53		S											
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RU						08-11-2017	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												KS							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		96	Downspout/Yard Hydrant		11
Building Drain - Sanitary		17	Foundation Drain to Clearwater		14
Building Overhang		8	Sewer - Building Sanitary		42
Clearwater Sump		15	Septic or Holding, or POWTS Tank		59

Comment:

Created On: 08-28-2017

Updated On: 10-01-2019

Review Status: