Well Construction Report
WISCONSIN UNIQUE WELL NUMBER YA113

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KANAS, TOM			Phone #: (262)388-5798
Mailing Address: N9301 N POLE RD			
City: THERESA	State: WI	Zip Code: 53091	
County: Dodge	Co. Permit #:	Notification #: 6897576701	Completed: 08-02-2017

Well Constructor (Business Name): RICHARD L UMLAND	Lic. #: 89	Facility ID # (Public Wells):	
Address: RICKS WELL & PUMP SERVICE MAYVILLE WI 53050		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of HUBBARD

Fire # (if avail.): N6251

Street Address or Road Name and Number: N6251 E NEDA RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.41895 °N -88.53542 °W	GPS008

SE SW or Govt Lot #	Section	Township	Range
	13	11 N	16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	53
6	53	67

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation ..... No
No Rotary - Air ..... Yes
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T - P -	BROWN HARD PAN	Surface	9
G - C -	GRAY CLAY	9	53
G - H -	DARK GRAY SHALE	53	67

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK P.E. 18.97 LBS/FT. A-53 G-B WHEATLAND STEEL	Surface	54
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 10 GP M for 0.5 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	53	S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RU		08-11-2017
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		96
Building Drain - Sanitary		17
Building Overhang		8
Clearwater Sump		15

Type	Qualifier	Distance
Downspout/Yard Hydrant		11
Foundation Drain to Clearwater		14
Sewer - Building Sanitary		42
Septic or Holding, or POWTS Tank		59

Comment:

Created On: 08-28-2017 Updated On: 10-01-2019 Review Status: